



April 25, 2024

Mr. Johnny Mills  
Operations Manager  
1617 JFK Blvd., Suite 580  
Philadelphia, PA 19103

RE: Lead (Pb) in Water Testing  
Freire Charter School Wilmington  
201 W 14<sup>th</sup> Street, Wilmington, DE 19801  
IEC Project # 2024.059.4

Dear Mr. Mills:

Indoor Environmental Concepts, LLC (IEC) was retained by the Freire Charter Schools to perform an assessment and testing of the drinking water outlets servicing the Freire Charter School Wilmington for the presence of lead (Pb). The lead in water testing was performed pursuant to the regulations and guidance documents from Delaware's Division of Public Health and Delaware's Department of Education and the United States Environmental Protection Agency (EPA) protocols as recommended in their publication 3Ts for Reducing Lead in Drinking Water in Schools, Revised Technical Guidance. The EPA developed the 3Ts for Reducing Lead in Drinking Water in Schools, Revised Technical Guidance, which has been incorporated into this sampling protocol because the Agency is concerned about the potential for elevated lead levels in drinking water in schools.

### **Safe Drinking Water Compliance**

The EPA recommends that schools collect 250 mL first-draw samples from water fountains, water bottle filler stations and potable water outlets for the analysis for lead (Pb). The EPA also recommends that these potable water outlets do not exceed 20 parts per billion (ppb) or 0.020 milligrams of lead per liter of water (mg/L). However, to guarantee that students have access to safe drinking water at Delaware schools, The action level used by the Delaware Codes is **7.5 parts per billion (ppb)** of lead. The action level of 7.5 ppb of lead or less was used in the interpretation of results for the samples collected and analyzed at the Freire Charter School Wilmington.

### **Lead Sampling Collection and Results**

A trained technician collected samples from water outlets and the samples were sent to a certified laboratory for analysis. The samples were collected after an 8-to-18-hour stagnation period. All samples were taken before the facility opened and before any water was used by building occupants. Where practical and feasible, samples were first collected at drinking water outlets that were as close as possible to the building water main. Cold water lines were sampled when possible. All water samples were collected in laboratory supplied, pre-cleaned 250 milliliter (mL) bottles preserved with Nitric Acid

(HNO<sub>3</sub>). The bottles were labeled with a unique sample identification number and the sample location and time sampled were recorded on the chain of custody form. All samples were sealed immediately after collection and delivered to the laboratory for the analysis of lead content via ICP/MS by EPA Method 200.8. A copy of the laboratory analytical reports, certifications, and chain of custody forms can be found as attachments to this report.

**First-draw sampling was performed by IEC at forty-one (41) drinking water outlets on April 5, 2024. Of those outlets, sample 0405-42 collected from the main building ground level women's lavatory and sample 0405-44 main building ground level men's lavatory inside left both failed. All other sampled outlets were reported to have a lead concentration below the action level of 7.5 ppb.**

In general, an ongoing flushing program should be implemented as a routine practice to improve the overall water quality at this facility. Flushing involves opening taps and letting the water run to remove water that has been standing in the interior pipes and/or the outlets. The flushing time can vary by the type of outlet being cleared. The degree to which flushing helps reduce lead levels can also vary depending upon the age and condition of the plumbing and the corrosiveness of the water. Flushing individual outlets immediately prior to use is recommended in conjunction with signage and flushing schedules. In addition, EPA recommends locating the faucet furthest away from the service line on each wing and floor of the building, opening the faucets, and let the water run for 10 minutes.

In summary, the assessment and testing performed indicate that the lead levels of the drinking water outlets servicing the school currently meet federal and State of Delaware guidelines, following the recommendations and provisions described herein.

## **Background**

Historically, 15 ppb has been the EPA's stated action level, and an enforceable standard, for lead in drinking water under the [EPA's Lead and Copper Rule regulations](#). It was also the stated level of action in the 2020 grant awarded to DPH and DOE. **Delaware has lowered the initial action level from 15 ppb to 7.5 ppb.**

Given the health effects of lead, EPA advocates that any school conducting sampling for lead make public any test results. In addition, such schools should identify activities they are pursuing to correct any lead problems. Advice, suggestions, and samples to assist in the public notification process is available from the EPA in their 3Ts for Reducing Lead in Drinking Water in Schools. This publication is available online on the EPA's website.

Sincerely:

*Indoor Environmental Concepts, LLC*



Michael P. Menz, CIH, CHMM

President

Attachments

AC12943



Project Name: Freire Wilmington

File #: 2024.059.4

Laboratory: EMSL

Analysis: Lead in Drinking Water – 200.8/6020A

Turnaround Time: 2 week

Collected by: Michael Menz

Date: April 5, 2024

Transmitted by: Michael Menz

Date: 4/5/24 10:05pm

Received by: Chelene WI

Date: 4/5/24 10:05

Sample #	Location	Fixture Type	Time sampled
1	0405-01 Kitchen 115 B left sink	S	8:12
2	0405-02 Kitchen 115 B far right sink	S	8:13
3	0405-03 Café... sink o/s 115 B	S	8:14
4	0405-04 Café... <del>bubbler</del> chiller	WC	8:16
5	0405-05 Café... water bottle filler	BF	8:17
6	0405-06 101 Office sink	S	8:19
7	0405-07 First floor hallway bubbler chiller	WC	8:19
8	0405-08 <del>First sink left</del> women's bathroom 1 <sup>st</sup> floor	S	8:20
9	0405-09 <del>Left sink</del> men's bathroom 1 <sup>st</sup> floor	S	8:21
	<del>0405-10 108 nurse's office sink</del> LOCKED	<del>S</del>	
10	0405-11 Staff restroom 1 <sup>st</sup> floor sink	S	8:25
11	0405-12 2 <sup>nd</sup> floor womens bathroom	S	8:28
12	0405-13 Hallway 2 <sup>nd</sup> floor water fountain bottle filler W cooler	WC	8:29
13	0405-14 2 <sup>nd</sup> floor staff bathroom sink	S	8:30
14	0405-15 2 <sup>nd</sup> floor water fountain bubbler (across 206) cooler	WC	8:31
15	0405-16 2 <sup>nd</sup> floor water fountain bottle filler (across 206)	BF	8:32
16	0405-17 213 nurse sink	S	8:32
17	0405-18 2 <sup>nd</sup> floor men's bathroom	S	8:33
18	0405-19 3 <sup>rd</sup> floor water fountain bubbler (next to elevator) <del>cooler</del> Bubbler	WC (B)	8:34

*Michael Menz* 4/05/24 9:30am of 2  
 RORY PWS. (WI)

AC12943

Freire Wilmington

19	0405-20	3 <sup>rd</sup> floor staff bathroom sink	S	8:37
20	0405-21	3 <sup>rd</sup> floor hallway water fountain <sup>water cooler</sup> bubbler (across 306)	WC	8:31
21	0405-22	3 <sup>rd</sup> floor hallway water fountain bottle filler (across 306)	BF	8:38
	<del>0405-23</del>	309 science lab		
22	0405-24	3 <sup>rd</sup> floor men's bathroom	S	8:39
23	0405-25	3 <sup>rd</sup> floor women's bathroom	S	8:40
24	0405-26	4 <sup>th</sup> floor women's bathroom	S	8:42
25	0405-27	4 <sup>th</sup> floor hallway water fountain <sup>cup filler</sup> bubbler (next to elevator)	B	8:43
	<del>0405-28</del>	<del>4<sup>th</sup> floor hallway water fountain bottle filler (next to elevator)</del>		
26	0405-29	4 <sup>th</sup> floor staff bathroom sink	S	8:45
27	0405-30	4 <sup>th</sup> floor men's bathroom	S	8:46
28	0405-31	4 <sup>th</sup> floor water fountain <sup>water cooler</sup> bubbler (across from 406)	WC	8:47
29	0405-32	4 <sup>th</sup> floor hallway water fountain bottle filler (across from 406)	BF	8:47
30	0405-33	gym; women's bathroom	S	8:51
31	0405-34	gym men's bathroom	S	8:52
32	0405-35	gym, disabled person bathroom	S	8:53
33	0405-36	gym, right water cooler	WC	8:54
34	0405-37	gym left water cooler	WC	8:55
35	0405-38	bottler filler	BF	8:56
36	0405-39	Locker room #1	S	8:58
37	0405-40	Locker room #2	S	8:59
38	0405-41	main bldg. ground level water cooler	WS	9:03
39	0405-42	" " " " women lavatory	S	9:04
40	0405-43	" " " " men lavatory	S	9:06
41	0405-44	men lavatory, inside left	S	9:07

Email results to:

[labresults@indoorenvconcepts.com](mailto:labresults@indoorenvconcepts.com)

Page 2 of 2

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:856-786-5974  
 EMSL-CIN-01

**EMSL Order ID:** 012412943  
**LIMS Reference ID:** AC12943  
**EMSL Customer ID:** INDA25

**Attention:** Michael Menz  
 Indoor Environmental Concepts, LLC [INDA25]  
 117 N Black Horse Pike  
 Runnemede, NJ 08078  
 (856) 628-6020  
 mpmenz@indoorenvconcepts.com

**Project Name:** Freire Wilmington  
**Customer PO:**  
**EMSL Sales Rep:** Gary Perlmutter  
**Received:** 04/05/2024 09:30  
**Reported:** 04/19/2024 17:20

**Analytical Results**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 0405-01/Kitchen 115 B left sink      Lims Reference ID: AC12943-01 Matrix: Drinking Water      Sampled: 04/05/24 08:12:00									
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	04/10/24 13:50	04/15/24 19:21	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: 0405-02/Kitchen 115 B far right sink      Lims Reference ID: AC12943-02 Matrix: Drinking Water      Sampled: 04/05/24 08:13:00									
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	04/10/24 13:50	04/15/24 19:26	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: 0405-03/Cafe....sink o/s 115 B      Lims Reference ID: AC12943-03 Matrix: Drinking Water      Sampled: 04/05/24 08:14:00									
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	04/10/24 13:50	04/15/24 19:28	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: 0405-04/Cafe....chiller      Lims Reference ID: AC12943-04 Matrix: Drinking Water      Sampled: 04/05/24 08:16:00									
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	04/10/24 13:50	04/15/24 19:30	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: 0405-05/Cafe....water bottle filler      Lims Reference ID: AC12943-05 Matrix: Drinking Water      Sampled: 04/05/24 08:17:00									
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	04/10/24 13:50	04/15/24 19:32	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: 0405-06/101 Office sink      Lims Reference ID: AC12943-06 Matrix: Drinking Water      Sampled: 04/05/24 08:19:00									
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	04/10/24 13:50	04/15/24 19:40	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: 0405-07/First floor hallway chiller      Lims Reference ID: AC12943-07 Matrix: Drinking Water      Sampled: 04/05/24 08:19:00									
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	04/10/24 13:50	04/16/24 11:27	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: 0405-08/Women's bathroom 1st floor      Lims Reference ID: AC12943-08 Matrix: Drinking Water      Sampled: 04/05/24 08:20:00									
<b>Metals</b>									
Lead	2.12		1	1.00	µg/L	04/10/24 13:50	04/15/24 19:46	LXK	EPA 200.8 (DA)/EPA 200.8
Sample: 0405-09/Men's bathroom 1st floor      Lims Reference ID: AC12943-09 Matrix: Drinking Water      Sampled: 04/05/24 08:21:00									
<b>Metals</b>									
Lead	1.06		1	1.00	µg/L	04/10/24 13:50	04/15/24 19:48	LXK	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:856-786-5974  
 EMSL-CIN-01

**EMSL Order ID:** 012412943  
**LIMS Reference ID:** AC12943  
**EMSL Customer ID:** INDA25

**Attention:** Michael Menz  
 Indoor Environmental Concepts, LLC [INDA25]  
 117 N Black Horse Pike  
 Runnemede, NJ 08078  
 (856) 628-6020  
 mpmenz@indoorenvconcepts.com

**Project Name:** Freire Wilmington  
**Customer PO:**  
**EMSL Sales Rep:** Gary Perlmutter  
**Received:** 04/05/2024 09:30  
**Reported:** 04/19/2024 17:20

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
<b>Sample: 0405-11/Staff restroom 1st floor sink</b>									
				<b>Lims Reference ID:</b>	<b>AC12943-10</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 04/05/24 08:25:00</b>	
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	04/10/24 13:50	04/15/24 19:50	LXK	EPA 200.8 (DA)/EPA 200.8
<b>Sample: 0405-12/2nd floor womens bathroom</b>									
				<b>Lims Reference ID:</b>	<b>AC12943-11</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 04/05/24 08:28:00</b>	
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	04/10/24 13:50	04/15/24 19:52	LXK	EPA 200.8 (DA)/EPA 200.8
<b>Sample: 0405-13/Hallway 2nd floor water cooler</b>									
				<b>Lims Reference ID:</b>	<b>AC12943-12</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 04/05/24 08:29:00</b>	
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	04/10/24 13:50	04/15/24 19:58	LXK	EPA 200.8 (DA)/EPA 200.8
<b>Sample: 0405-14/2nd floor staff bathroom sink</b>									
				<b>Lims Reference ID:</b>	<b>AC12943-13</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 04/05/24 08:30:00</b>	
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	04/10/24 13:50	04/15/24 20:00	LXK	EPA 200.8 (DA)/EPA 200.8
<b>Sample: 0405-15/2nd floor water fountain (across 206) cooler</b>									
				<b>Lims Reference ID:</b>	<b>AC12943-14</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 04/05/24 08:31:00</b>	
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	04/10/24 13:50	04/15/24 20:10	LXK	EPA 200.8 (DA)/EPA 200.8
<b>Sample: 0405-16/2nd floor water fountain bottle filler (across 206)</b>									
				<b>Lims Reference ID:</b>	<b>AC12943-15</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 04/05/24 08:32:00</b>	
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	04/10/24 13:50	04/15/24 20:12	LXK	EPA 200.8 (DA)/EPA 200.8
<b>Sample: 0405-17/213 nurse sink</b>									
				<b>Lims Reference ID:</b>	<b>AC12943-16</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 04/05/24 08:32:00</b>	
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	04/10/24 13:50	04/15/24 20:14	LXK	EPA 200.8 (DA)/EPA 200.8
<b>Sample: 0405-18/2nd floor men's bathroom</b>									
				<b>Lims Reference ID:</b>	<b>AC12943-17</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 04/05/24 08:33:00</b>	
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	04/10/24 13:50	04/15/24 20:16	LXK	EPA 200.8 (DA)/EPA 200.8
<b>Sample: 0405-19/3rd floor water fountain (next to elevator) bubbler</b>									
				<b>Lims Reference ID:</b>	<b>AC12943-18</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 04/05/24 08:34:00</b>	
<b>Metals</b>									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:856-786-5974  
 EMSL-CIN-01

**EMSL Order ID:** 012412943  
**LIMS Reference ID:** AC12943  
**EMSL Customer ID:** INDA25

**Attention:** Michael Menz  
 Indoor Environmental Concepts, LLC [INDA25]  
 117 N Black Horse Pike  
 Runnemede, NJ 08078  
 (856) 628-6020  
 mpmenz@indoorenvconcepts.com

**Project Name:** Freire Wilmington  
**Customer PO:**  
**EMSL Sales Rep:** Gary Perlmutter  
**Received:** 04/05/2024 09:30  
**Reported:** 04/19/2024 17:20

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
<b>Sample: 0405-19/3rd floor water fountain (next to elevator) bubbler (Continued)</b>									
			<b>Lims Reference ID:</b>		<b>AC12943-18</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 04/05/24 08:34:00</b>	
<b>Metals (Continued)</b>									
Lead	<1.00		1	1.00	µg/L	04/10/24 13:50	04/15/24 20:19	LXK	EPA 200.8 (DA)/EPA 200.8
<b>Sample: 0405-20/3rd floor staff bathroom sink</b>									
			<b>Lims Reference ID:</b>		<b>AC12943-19</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 04/05/24 08:37:00</b>	
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	04/10/24 13:50	04/15/24 20:21	LXK	EPA 200.8 (DA)/EPA 200.8
<b>Sample: 0405-21/3rd floor hallway water fountain water cooler (across 306)</b>									
			<b>Lims Reference ID:</b>		<b>AC12943-20</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 04/05/24 08:37:00</b>	
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	04/10/24 13:50	04/15/24 20:23	LXK	EPA 200.8 (DA)/EPA 200.8
<b>Sample: 0405-22/3rd floor hallway water fountain bottle filler (across 306)</b>									
			<b>Lims Reference ID:</b>		<b>AC12943-21</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 04/05/24 08:38:00</b>	
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	04/10/24 16:33	04/15/24 20:39	LXK	EPA 200.8 (DA)/EPA 200.8
<b>Sample: 0405-24/3rd floor men's bathroom</b>									
			<b>Lims Reference ID:</b>		<b>AC12943-22</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 04/05/24 08:39:00</b>	
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	04/10/24 16:33	04/15/24 20:45	LXK	EPA 200.8 (DA)/EPA 200.8
<b>Sample: 0405-25/3rd floor women's bathroom</b>									
			<b>Lims Reference ID:</b>		<b>AC12943-23</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 04/05/24 08:40:00</b>	
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	04/10/24 16:33	04/15/24 20:47	LXK	EPA 200.8 (DA)/EPA 200.8
<b>Sample: 0405-26/4th floor women's bathroom</b>									
			<b>Lims Reference ID:</b>		<b>AC12943-24</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 04/05/24 08:42:00</b>	
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	04/10/24 16:33	04/15/24 20:49	LXK	EPA 200.8 (DA)/EPA 200.8
<b>Sample: 0405-27/4th floor hallway water fountain cup filler (next to elevator)</b>									
			<b>Lims Reference ID:</b>		<b>AC12943-25</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 04/05/24 08:43:00</b>	
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	04/10/24 16:33	04/15/24 20:51	LXK	EPA 200.8 (DA)/EPA 200.8
<b>Sample: 0405-29/4th floor staff bathroom sink</b>									
			<b>Lims Reference ID:</b>		<b>AC12943-26</b>	<b>Matrix: Drinking Water</b>		<b>Sampled: 04/05/24 08:45:00</b>	

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:856-786-5974  
 EMSL-CIN-01

**EMSL Order ID:** 012412943  
**LIMS Reference ID:** AC12943  
**EMSL Customer ID:** INDA25

**Attention:** Michael Menz  
 Indoor Environmental Concepts, LLC [INDA25]  
 117 N Black Horse Pike  
 Runnemede, NJ 08078  
 (856) 628-6020  
 mpmenz@indoorenvconcepts.com

**Project Name:** Freire Wilmington  
**Customer PO:**  
**EMSL Sales Rep:** Gary Perlmutter  
**Received:** 04/05/2024 09:30  
**Reported:** 04/19/2024 17:20

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
<b>Sample: 0405-29/4th floor staff bathroom sink (Continued)</b> <b>Lims Reference ID: AC12943-26 Matrix: Drinking Water</b> <b>Sampled: 04/05/24 08:45:00</b>									
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	04/10/24 16:33	04/15/24 20:57	LXK	EPA 200.8 (DA)/EPA 200.8
<b>Sample: 0405-30/4th floor men's bathroom</b> <b>Lims Reference ID: AC12943-27 Matrix: Drinking Water</b> <b>Sampled: 04/05/24 08:46:00</b>									
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	04/10/24 16:33	04/15/24 20:59	LXK	EPA 200.8 (DA)/EPA 200.8
<b>Sample: 0405-31/4th floor water fountain water cooler (across from 406)</b> <b>Lims Reference ID: AC12943-28 Matrix: Drinking Water</b> <b>Sampled: 04/05/24 08:47:00</b>									
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	04/10/24 16:33	04/15/24 21:01	LXK	EPA 200.8 (DA)/EPA 200.8
<b>Sample: 0405-32/4th floor hallway water fountain bottle filler (across from 406)</b> <b>Lims Reference ID: AC12943-29 Matrix: Drinking Water</b> <b>Sampled: 04/05/24 08:47:00</b>									
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	04/10/24 16:33	04/15/24 21:03	LXK	EPA 200.8 (DA)/EPA 200.8
<b>Sample: 0405-33/Lobby gym women's bathroom</b> <b>Lims Reference ID: AC12943-30 Matrix: Drinking Water</b> <b>Sampled: 04/05/24 08:51:00</b>									
<b>Metals</b>									
Lead	7.03		1	1.00	µg/L	04/10/24 16:33	04/15/24 21:06	LXK	EPA 200.8 (DA)/EPA 200.8
<b>Sample: 0405-34/Lobby gym men's bathroom</b> <b>Lims Reference ID: AC12943-31 Matrix: Drinking Water</b> <b>Sampled: 04/05/24 08:52:00</b>									
<b>Metals</b>									
Lead	3.03		1	1.00	µg/L	04/10/24 16:33	04/15/24 21:08	LXK	EPA 200.8 (DA)/EPA 200.8
<b>Sample: 0405-35/Lobby gym disabled person bathroom</b> <b>Lims Reference ID: AC12943-32 Matrix: Drinking Water</b> <b>Sampled: 04/05/24 08:53:00</b>									
<b>Metals</b>									
Lead	3.78		1	1.00	µg/L	04/10/24 16:33	04/15/24 21:14	LXK	EPA 200.8 (DA)/EPA 200.8
<b>Sample: 0405-36/Lobby gym right water cooler</b> <b>Lims Reference ID: AC12943-33 Matrix: Drinking Water</b> <b>Sampled: 04/05/24 08:54:00</b>									
<b>Metals</b>									
Lead	1.22		1	1.00	µg/L	04/10/24 16:33	04/15/24 21:16	LXK	EPA 200.8 (DA)/EPA 200.8
<b>Sample: 0405-37/Lobby gym left water cooler</b> <b>Lims Reference ID: AC12943-34 Matrix: Drinking Water</b> <b>Sampled: 04/05/24 08:55:00</b>									



**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:856-786-5974  
 EMSL-CIN-01

**EMSL Order ID:** 012412943  
**LIMS Reference ID:** AC12943  
**EMSL Customer ID:** INDA25

**Attention:** Michael Menz  
 Indoor Environmental Concepts, LLC [INDA25]  
 117 N Black Horse Pike  
 Runnemede, NJ 08078  
 (856) 628-6020  
 mpmenz@indoorenvconcepts.com

**Project Name:** Freire Wilmington  
**Customer PO:**  
**EMSL Sales Rep:** Gary Perlmutter  
**Received:** 04/05/2024 09:30  
**Reported:** 04/19/2024 17:20

### Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
<b>Sample: 0405-37/Lobby gym left water cooler (Continued)</b> <b>Lims Reference ID: AC12943-34 Matrix: Drinking Water</b> <b>Sampled: 04/05/24 08:55:00</b>									
<b>Metals</b>									
Lead	1.60		1	1.00	µg/L	04/10/24 16:33	04/15/24 21:22	LXK	EPA 200.8 (DA)/EPA 200.8
<b>Sample: 0405-38/Lobby gym left bottle filler</b> <b>Lims Reference ID: AC12943-35 Matrix: Drinking Water</b> <b>Sampled: 04/05/24 08:57:00</b>									
<b>Metals</b>									
Lead	1.54		1	1.00	µg/L	04/10/24 16:33	04/15/24 21:24	LXK	EPA 200.8 (DA)/EPA 200.8
<b>Sample: 0405-39/Locker room #1</b> <b>Lims Reference ID: AC12943-36 Matrix: Drinking Water</b> <b>Sampled: 04/05/24 08:58:00</b>									
<b>Metals</b>									
Lead	2.90		1	1.00	µg/L	04/10/24 16:33	04/15/24 21:26	LXK	EPA 200.8 (DA)/EPA 200.8
<b>Sample: 0405-40/Locker room #2</b> <b>Lims Reference ID: AC12943-37 Matrix: Drinking Water</b> <b>Sampled: 04/05/24 08:59:00</b>									
<b>Metals</b>									
Lead	5.09		1	1.00	µg/L	04/10/24 16:33	04/15/24 21:28	LXK	EPA 200.8 (DA)/EPA 200.8
<b>Sample: 0405-41/Main bldg ground level water cooler</b> <b>Lims Reference ID: AC12943-38 Matrix: Drinking Water</b> <b>Sampled: 04/05/24 09:03:00</b>									
<b>Metals</b>									
Lead	<1.00		1	1.00	µg/L	04/10/24 16:33	04/15/24 21:30	LXK	EPA 200.8 (DA)/EPA 200.8
<b>Sample: 0405-42/Main bldg ground level women lavatory</b> <b>Lims Reference ID: AC12943-39 Matrix: Drinking Water</b> <b>Sampled: 04/05/24 09:04:00</b>									
<b>Metals</b>									
Lead	14.9		1	1.00	µg/L	04/10/24 16:33	04/15/24 21:32	LXK	EPA 200.8 (DA)/EPA 200.8
<b>Sample: 0405-43/Main bldg ground level men lavatory</b> <b>Lims Reference ID: AC12943-40 Matrix: Drinking Water</b> <b>Sampled: 04/05/24 09:06:00</b>									
<b>Metals</b>									
Lead	7.46		1	1.00	µg/L	04/10/24 16:33	04/15/24 21:34	LXK	EPA 200.8 (DA)/EPA 200.8
<b>Sample: 0405-44/Main bldg ground level men lavatory inside left</b> <b>Lims Reference ID: AC12943-41 Matrix: Drinking Water</b> <b>Sampled: 04/05/24 09:07:00</b>									
<b>Metals</b>									
Lead	10.9		1	1.00	µg/L	04/11/24 11:43	04/11/24 14:41	LXK	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
 Telephone: 856-858-4800 Fax:856-786-5974  
 EMSL-CIN-01

**EMSL Order ID:** 012412943  
**LIMS Reference ID:** AC12943  
**EMSL Customer ID:** INDA25

**Attention:** Michael Menz  
 Indoor Environmental Concepts, LLC [INDA25]  
 117 N Black Horse Pike  
 Runnemede, NJ 08078  
 (856) 628-6020  
 mpmenz@indoorenvconcepts.com

**Project Name:** Freire Wilmington

**Customer PO:**  
**EMSL Sales Rep:** Gary Perlmutter

**Received:** 04/05/2024 09:30

**Reported:** 04/19/2024 17:20

**Certified Analyses included in this Report**

Analyte	Certifications
<b>EPA 200.8 in Drinking Water</b>	
Lead	NJDEP

**List of Certifications**

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	68-00367	11/30/2024
NYSDOH	New York State Department of Health	10872	04/01/2025
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2024
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2024
CTDPH	Connecticut Department of Public Health	PH-0270	06/23/2024
California ELAP	California Water Boards	1877	06/30/2024
AIHA LAP	EMSL Analytical, Inc. Cinnaminson, NJ AIHA-LAP, LLC-ELLAP Accredited	100194	01/01/2025
A2LA	A2LA Environmental Certificate	2845.01	07/31/2024

Please see the specific Field of Testing (FOT) on [www.emsl.com](http://www.emsl.com) <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077  
Telephone: 856-858-4800 Fax:856-786-5974  
EMSL-CIN-01

**EMSL Order ID:** 012412943  
**LIMS Reference ID:** AC12943  
**EMSL Customer ID:** INDA25

**Attention:** Michael Menz  
Indoor Environmental Concepts, LLC [INDA25]  
117 N Black Horse Pike  
Runnemede, NJ 08078  
(856) 628-6020  
mpmenz@indoorenvconcepts.com

**Project Name:** Freire Wilmington

**Customer PO:**  
**EMSL Sales Rep:** Gary Perlmutter

**Received:** 04/05/2024 09:30

**Reported:** 04/19/2024 17:20

**Notes and Definitions**

<b>Item</b>	<b>Definition</b>
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
Q	Qualifier
RL	Reporting Limit

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted."